



Date: April 30, 2026
To: Potential Offerors
From: H. Frank Schneider, Senior Contract Manager
Re: 26-0385 RFP HHSC HBMC NEW PA SYSTEM PROJECT SOLICITATION ADDENDUM No. 01
Questions & Answers.

This correspondence serves as Solicitation Addendum No. 01 to the subject Request for Proposal (“RFP”).

Your response to this RFP should be governed by the content of the original RFP and the revisions / corrections / additions / clarifications provided in this addendum notice.

The RFP is amended.

RFP 26-0385, issued April 10, 2026, is updated with the information provided within this Solicitation Addendum No. 01.


QUESTIONS & ANSWERS:

Q1. It was mentioned on site that all 120VAC electrical provisions at head-end locations will be handled by HBMC Facilities team. Please confirm.

A1. Confirmed at all head-end 120vac quadplex by HBMC. Confirmed by HBMC electrical dept -GPS confirms.

Q2. On sheet PA1-02, it shows the headend location in ELEC 2B 43, however during the walk it was requested this move to STOR 2A-55A due to space limitations. Please confirm.

A2. We opened the closet at the walkthrough there appears to be space. Please revise drawing.




Previously had STOR 2A-55A earmarked for a headend but this HBMC comment from 8/6/2025 led me to believe that was not wanted. Glad to make the move if desired. Please confirm this is wanted as it changes the drawings quite a bit. Confirming - ELEC 2B 43 will no longer be used.

Q3. On sheet PA3-01, there are no speakers shown in the Health Connect Office. Discussion was to add (3) speakers to this building. Please Confirm.

A3. We thought there was PA speaker for the Epic/Healthconnect office. We did

originally have one there, Confirming that the Epic/Healthconnect office requires (3) PA speakers.




Q4. Maintenance Trailer not shown on plans. Request was to add (1) speaker to this location. Please confirm.

A4. Confirmed, in the maintenance trailer, the area was overlooked-add (1) speaker.

Q5. Current installation at Maintenance Shop is open cabling. A request to provide an add-alternate for this area to be in conduit was made. Please confirm.

A5. Confirmed. Requested by HBMC Facilities as option. See figure provided below in this answer.



1 PUBLIC ADDRESS PLAN - MAINTENANCE SHOP & LR NEW HEALTH CONNECT OFFICE
V09 - 1-3

Except as noted above, the RFP 26-0385 is unchanged.

Date: May 15, 2026
To: Potential Offerors
From: H. Frank Schneider, Senior Contract Manager
Re: 26-0385 RFP HHSC HBMC NEW PA SYSTEM PROJECT SOLICITATION ADDENDUM No. 02
New Drawings and Adjusted Procurement Timetable.

This correspondence serves as Solicitation Addendum No. 02 to the subject Request for Proposal (“RFP”).

Your response to this RFP should be governed by the content of the original RFP and the revisions / corrections / additions / clarifications provided in this addendum notice.

The RFP is amended.

RFP 26-0385, issued April 10, 2026, is updated with the information provided within this Solicitation Addendum No. 02.

ADDITIONAL DRAWINGS: ***All potential offerors responding to RFP 26-0385 are hereby advised to incorporate the currently available Drawing Set, which includes supplemental and revised requirements affecting the completed PA System. Additional information regarding the updated Drawing Set, including access for review and download, is available through the ShareFile link provided herein. The referenced link shall remain accessible through August 9, 2026.***

<https://hawaiihealthsystemcorporation.sharefile.com/public/share/web-s39e31294781c4bd4bc6a0c5467730581>

ADJUSTED TIMETABLE: *** The Procurement Timetable set forth in Section 1.2 of RFP 26-0385 is hereby revised as outlined in the table provided below within Solicitation Addendum No. 02.***

ACTIVITY		SCHEDULED DATES
5.	Closing Date for Receipt of Proposals	Friday, May 22, 2026 - No Later Than 2:00 p.m., HST
6.	Proposal Evaluations	May 25-29, 2026
7.	Proposal Discussions (optional)	June 1-5, 2026
8.	Best and Final Offers (optional)	June 1-5, 2026
9.	CONTRACTOR Selection/Award Notification (on/about)	June 12, 2026
10.	Contract Start Date	TBD

Except as noted above, the RFP 26-0385 is unchanged.